

Cement

NewCem Plus

Analysis by: Lafarge Concrete Lab
 Sample from : Seattle Blending Facility
 Average Analysis: April 2021
 Mill Certificate ID: 5-21 BSCM



Chemical Analysis

Total Alkalies as Equivalent Na ₂ O	2.24 %
CaO Fly Ash *	15 %
SO ₃ Fly Ash *	1.0 %
SO ₃ Slag **	2.1 %
S Ion Slag **	0.8 %

Physical Analysis

Ground Granulated Blast Furnace Slag SAI, 28 Day **	100 %
Class/Type F Fly Ash Pozzolanic Activity Index, 28 Day *	92 %
LOI Fly Ash *	0.29 %
Autoclave Fly Ash *	0.05 %
Autoclave Slag **	0.01 %
45 _u Fly Ash*	20.0 %
45 _u Slag**	9.1 %
Density	2.78 Mg/m ³

Cementitious Blend

Class/Type F Fly Ash Blend Percentage	50 %
Ground Granulated Blast Furnace Slag Blend Percentage	50 %

We hereby certify this blended SCM product meets the requirements of ASTM C-1697 SCMb-50S/50F and CSA A-3000 Bmb-50F/S.

Certified : 

Rob Shogren, P.E.
 Technical Engineer
 Lafarge North America

* 5-21F Centralia Class/Type F Fly Ash Cert

** SEA_NEWCEM_May2021 Ground Granulated Blast Furnace Slag Cert