



# TerraFlow® Mill Test Report

Month of Issue: SEPTBEMBER 2021

Plant: Seattle, Washington  
Product: TerraFlow 75  
Manufactured: AUGUST 2021  
Mill Test Report Number: TerraFlow75\_SEPTBEMBER 2021

## ASTM C 1157 Standard Requirements

CHEMICAL ANALYSIS			PHYSICAL ANALYSIS		
Item	Spec limit	Test Result	Item	Spec limit	Test Result
Slag, %	---	75	Passing 325 Sieve (%)	---	96.1
Type IL, %	---	25	Autoclave expansion (%)	0.8	-0.05
			Compressive strength (MPa)		
			3 days	5.0 min	15.0
			7 days	11.0 min	24.0
			28 days	--	35.6

We certify that the above described cement, at the time of shipment, meets the chemical and physical requirements of applicable Specifications for Type MH

Seattle Plant  
5400 W. Marginal Way SW, Seattle, WA 98106  
Phone: 206-937-8025

Certified By:

Daniel Waldron - QC Laboratory Supervisor

September 15, 2021