

Mill Test Report Number: SEA\_NEWCEM\_DECEMBER2021

YEAR: 2021 MONTH: DECEMBER PLANT: Seattle

**CEMENT TYPE: NewCem Grade 100** 

Slag

Reference Cement				
Fineness by Air Permeability (m²/kg; ASTM C204)	374			
Fineness by 45 µm (No. 325) Sieve (% retain; ASTM C430)	2.57			
Compressive Strength (ASTM C109/C109 M) 7-day 28-day	<b>psi</b> 5,240 6,190	Min Limit - 5,000		
Total Alkalies (Na <sub>2</sub> O + 0.658 K <sub>2</sub> O) (%, ASTM C114)	<u>Actual</u> 0.89	<u>Limits</u> 0.6-0.9		

Percent
34.1
1.0
14.6
42.4
3.7
4.0
0.6
0.8
0.40
0.72
6

Fineness by Air Permeability (m²/kg; ASTM C204)	372		
Fineness by 45 µm (No. 325) Sieve (% retain; ASTM C430)	5.3		
Compressive Strength (ASTM C109/C109 M)	psi [Mpa]	<u>SAI</u>	SAI Limit <u>Min</u>
28-day (Previous Month)	5935 [40.9]	97	95
Specific Gravity (Mg/m³; ASTM C188)	2.87		
	Actual	Max	Limit
Air Content of Mortar (%, ASTM C185)	4.9	•	12
Sulfide Sulfur (% S, ASTM C114)	8.0	:	2.5
Sulfate Ion (% as SO3, ASTM C114)	1.7		A
Autoclave expansion (%, CSA A3004-B5)	-0.016		0.5
			l

The ground granulated blast furnace slag complies with the current specification of the chemical physical requirement of ASTM C-989, AASHTO M-302 for grade 100 Ground Granulated Blast Furace Slag (GGBFS) and and CSA A3001 Slag.

Slag source is JFE Mineral Company in Kurashiki City, Japan. NewCem is ground and manufactured in Seattle, WA.



Certified by:

Daniel Waldron

Quality Control Laboratory Supervisor

December 13, 2021

<sup>&</sup>lt;sup>A</sup> Not Applicable.