



TerraFlow® Mill Test Report

Month of Issue: March 2023

Plant: Seattle, Washington
Product: TerraFlow 75
Manufactured: February 2023
Mill Test Report Number: TerraFlow75_March2023

ASTM C 1157 Standard Requirements

CHEMICAL ANALYSIS

Item	Spec limit	Test Result
Slag, %	---	75
Type IL, %	---	25

PHYSICAL ANALYSIS

Item	Spec limit	Test Result
Passing 325 Sieve (%)	---	95.4
Autoclave expansion (%)	0.8	0.00
Compressive strength (MPa)		
3 days	5.0 min	11.2
7 days	11.0 min	23.8
28 days	--	36.1

We certify that the above described cement, at the time of shipment, meets the chemical and physical requirements of applicable Specifications for Type MH

Seattle Plant
5400 W. Marginal Way SW, Seattle, WA 98106
Phone: 206-937-8025

Certified By:

Rob Shogren Technical Director

March 2, 2023