

Cement Test Report

Mill Test Report Number: SEA_NEWCEM_January_2025

YEAR: 2024

MONTH OF PRODUCTION: December PLANT: Seattle

CEMENT TYPE: NewCem Grade 100

_	•		_	
Rei	tere	nce	Cem	1eni

Fineness by Air Permeability (m²/kg; ASTM C204)	434	
Fineness by 45 µm (No. 325) Sieve (% retain; ASTM C430)	2.4	
Compressive Strength (ASTM C109/C109 M) 7-day 28-day	psi 4,730 5,900	Min Limit - 5,000
Total Alkalies (Na₂O + 0.658 K₂O) (%, ASTM C114)	<u>Actual</u> 0.86	<u>Limits</u> 0.6-0.9

Siag	Siag			
CHEMICAL ANALYSIS	Percent			
Silica Dioxide (SiO _{2;} ASTM C114)	32.2			
Ferric Oxide (Fe ₂ O _{3;} ASTM C114)	1.3			
Aluminum Oxide (Al ₂ O ₃ ; ASTM C114)	12.5			
Calcium Oxide (CaO; ASTM C114)	40.7			
Sulfur Trioxide (SO ₃ ; ASTM C114)	7.2			
Magnesium Oxide (MgO; ASTM C114)	4.5			
Loss on Ignition (L.O.I.; ASTM C114)	2.43			
Total Alkalies	0.72			
Inorganic Process Addition	9.6			

	Slag	
Fineness by Air Permeability (m²/kg; ASTM C204)	559	
Fineness by 45 μm (No. 325) Sieve (% retain; ASTM C430)	3.7	
Compressive Strength (ASTM C109/C109 M) 28-day (Previous Month)	SAI 102	SAI Limit <u>Min</u> 95
Specific Gravity (Mg/m³, ASTM C188)	2.86	
Air Content of Mortar (%, ASTM C185)	Actual 5	Max Limit 12
Sulfide Sulfur (% S, ASTM C114)	0.8	2.5
Sulfate Ion (% as SO3, ASTM C114)	6.4	A
Sulfate Expansion (% Expansion, ASTM C1038, CSA C5)	0.003	0.020
Color Value L*	77.6	

The ground granulated blast furnace slag complies with the current specification of the chemical physical requirement of ASTM C-989, AASHTO M-302 for grade 100 Ground Granulated Blast Furace Slag (GGBFS) and and CSA A3001 Slag.

Slag source is JFE Mineral Company in Kurashiki City, Japan. NewCem is ground and manufactured in Seattle, WA.



Certified by:

Rob Shogren Technical Director

December 26, 2024

A Not Applicable