



Cement

NewCem Plus



Certified to
NSF/ANSI/CAN 61

Analysis by: Lafarge Concrete Lab
Sample from : Seattle Blending Facility
Average Analysis: June 2025
Mill Certificate ID: 6-25 BSCM

Chemical Analysis

Total Alkalies as Equivalent Na ₂ O	2.19 %
CaO Fly Ash *	12.8 %
SO ₃ Fly Ash *	0.8 %
SO ₃ Slag **	6.6 %
S Ion Slag **	0.8 %


Physical Analysis

Ground Granulated Blast Furnace Slag SAI, 28 Day **	102 %
Class/Type F Fly Ash Pozzolanic Activity Index, 28 Day *	103 %
LOI Fly Ash *	0.57 %
45 _u Fly Ash*	14.4 %
45 _u Slag**	4.1 %
Density	2.76 Mg/m ³

Cementitious Blend

Class/Type F Fly Ash Blend Percentage	50 %
Ground Granulated Blast Furnace Slag Blend Percentage	50 %

We hereby certify this blended SCM product meets the requirements of
ASTM C-1697 SCMb-50S/50F and CSA A-3000 BMb-50F/S.

Certified : 
Rob Shogren, P.E.
Technical Engineer
Lafarge North America

* 4-25F Centralia Class/Type F Fly Ash Cert

** SEA_NEWCEM_June_2025 Ground Granulated Blast Furnace Slag Cert