



TerraFlow® Mill Test Report

Month of Issue: December 2025

Plant: Seattle, Washington
Product: TerraFlow 75
Manufactured: November 2025
Mill Test Report Number: TerraFlow75_December_2025

ASTM C 1157 Standard Requirements

CHEMICAL ANALYSIS			PHYSICAL ANALYSIS		
Item	Spec limit	Test Result	Item	Spec limit	Test Result
Slag, %	---	75	Passing 325 Sieve (%)	---	97.0
Type II, %	---	25	Blaine Fineness (m ² /kg) (C 204)	---	459
			Compressive strength (MPa)		
			3 days	5.0 min	12.8
			7 days	11.0 min	23.1
			28 days	--	38.4

We certify that the above described cement, at the time of shipment, meets the chemical and physical requirements of applicable Specifications for Type MH

Certified By:

Seattle Plant
5400 W. Marginal Way SW, Seattle, WA 98106
Phone: 206-937-8025

Rob Shogren Technical Director

July 16, 2025